



**MEHRAN UNIVERSITY OF ENGINEERING AND TECHNOLOGY**  
JAMSHORO - 76062, SINDH, PAKISTAN

(ISO-9001)  
Certified

**Engr: Munir A. Shaikh**

B.E. (Mech), MBA (Finance), M.A. (Eco)

Director Finance

No. MUET/PS/020/07/12

Dated: 16<sup>th</sup> July, 2012

The Director (CB)  
Government of Sindh,  
Sindh Public Procurement Regularity Authority,  
General Administration & Coordination Department  
Sindh Secretariat, Karachi.

Subject: **BID EVALUATION REPORTS.**

Reference: Mehran University Tender hoisted on SPPRA web site on 27-06-12 at  
**SPPRA Tender ID 8916/2012.**

Dear Sir,

With reference to your above tender, please find enclosed Bid Evaluation Reports of Tender for the Procurement of UPS 6KVA for Data Centre Established in the Department of Computer System Engineering and Printing of various items for Hostel MUET Jamshoro, with request to kindly hoist same on SPPRA website at the earliest. A copy of same has also been hoisted on University's Website.

Best Regards,

  
Director Finance

---


Telephone: +92-022-2771442, Fax: +92-022-2772531  
Email: munir\_a\_shaikh@yahoo.com df@muet.edu.pk

## Bid Evaluation Report


1. Name of Procuring Agency: Mehran University of Engineering & Technology, Jamshoro
2. Tender Reference No: MUET/PS/040/06/12 of 20<sup>th</sup> June, 2012.
3. Tender Description/Name of work/item: Procurement for UPS 6KVA for Dept of Computer Syst.
4. Method of Procurement: Open Competitive Bidding (Single Stage One Envelop Procedure)
5. Tender Published: MUET website on 25-06-12, SPPRA on 27-06-2012 vide SPPRA ID # 8916/2012.  
*Print & Electronic Media (SPPRA ID No. & News papers names with dates)*
6. Total Bid documents Sold: 03 (Three)
7. Total Bids Received: 03 (Three)
8. Technical Bid Opening date: (if applicable) Not applicable *(Provide details in separate form)*
9. No. of Bid technically qualified (if applicable): Not applicable
10. Bid(s) Rejected: Not applicable
11. Financial Bid Opening date: 12-07-2012


### 12. Bid Evaluation Report:

S No	Name of Firm or Bidder	Cost offered by the Bidder	Ranking in terms of cost	Comparison with Estimated cost	Reasons for acceptance/rejection	Remarks
0	1	2	3	4	5	6
1.	A					
2.	B	Comparative Statement showing all necessary information required in this format is enclosed as <b>Annexure-B</b>				
3.	C					

  
Prof. Dr. Mohd. Hayat Jokhio  
Member UPC  
BPS-21

  
Mr. Munir Ahmed Shaikh  
Director Finance / Member UPC  
BPS-20

  
Prof. Dr. Mukhtiar A. Unar  
Chairman, Dept of CS  
BPS-22

  
Mr. Abdull Jalil Khan  
Member UPC  
BPS-19

  
Mr. Mushtaqe Ahmed P.  
Purchase Officer/Member UPC  
BPS-18

**MEHRAN UNIVERSITY OF ENGINEERING & TECHNOLOGY, JAMSHORO.**  
**COMPARATIVE STATEMENT OF UPS 6-KVA FOR DATA CENTRE IN THE DEPT. OF COMPUTER SYSTEM**      ANNEXURE-B

<b>UPS (6 KVA) Technical Specifications</b>		Qty	M/s System Engineering, Karachi.		M/s Fire Safety & Security Lahore		M/s MAB Interface, Khi		<b>Remarks</b>
			Rate	Amount	Rate	Amount	Rate	Amount	
<b>GENERAL</b>									
User Interface	Graphical LCD with backlight and text in English								
Topology	Double conversion								
Diagnosis	Full system self-test								
<b>ELECTRICAL INPUT</b>									
Nominal Voltage	220V-240V (50Hz)								
Voltage Range	156-280V(40-70Hz)								
Power Draw of UPS (full load)	6000VA: 26A @230V								
Recommended Input Breaker Rating	35A								
<b>ELECTRICAL OUTPUT</b>									
Power Factor	0.7		165,000		170,000		150,000		
On Utility/ Battery Voltage	2% of nominal regulation				Eaton				
Efficiency	>97% in high efficiency mode, >91% in normal MODE				6 KVA APC, RTD-5000-XLI		Inform DSP-1106		
Load Crest Factor	3 to 1	02		330,000			6KVA Turkey		
<b>BATTERY</b>									
Internal Battery Type	5.5 Ah, sealed, lead-acid, maintenance free								
External Battery Type	5.5 Ah, sealed, lead-acid, maintenance free								
Battery Runtime	4 minutes with internal batteries @ 100% load								
Battery Recharge Time	6 hours to recover after 90% of nominal backup after 100% RCD load discharge								
Battery Replacement	Hot-Swappable internal and external batteries								
<b>COMMUNICATIONS</b>									
Serial USB Port	RS-232 as Standard with cable provided								
Relay Output	DB9 Dry contact-common alarm standard								
Software	For Power Manager								
<b>Total</b>				330,000/-		340,000/-		300,000/-	





The Technical Committee decided the M/s MAB Interface Karachi offers Inform DSP multi power series 6KVA unit and also the sole distributor of Inform UPS in Pakistan. may be recommended for procurement. As the same brand is already installed in various departments of the University and its performance is satisfactory.

## Bid Evaluation Report

1. Name of Procuring Agency: Mehran University of Engineering & Technology, Jamshoro
2. Tender Reference No: MUET/PS/040/06/12 of 20<sup>th</sup> June, 2012.
3. Tender Description/Name of work/item: Procurement for Printing of Various items for Hostels
4. Method of Procurement: Open Competitive Bidding (Single Stage One Envelop Procedure)
5. Tender Published: MUET website on 25-06-12, SPPRA on 27-06-2012 vide SPPRA ID # 8916/2012.  
*Print & Electronic Media (SPPRA ID No. & News papers names with dates)*
6. Total Bid documents Sold: 03 (Three)
7. Total Bids Received: 03 (Three)
8. Technical Bid Opening date: (if applicable) Not applicable *(Provide details in separate form)*
9. No. of Bid technically qualified (if applicable): Not applicable
10. Bid(s) Rejected: Not applicable
11. Financial Bid Opening date: 12-07-2012

### 12. Bid Evaluation Report:

S No	Name of Firm or Bidder	Cost offered by the Bidder	Ranking in terms of cost	Comparison with Estimated cost	Reasons for acceptance/rejection	Remarks
0	1	2	3	4	5	6
1.	A					
2.	B	Comparative Statement showing all necessary information required in this format is enclosed as <b>Annexure-A</b>				
3.	C					



Prof. Dr. Mohd. Hayat Jokhio  
Member UPC  
BPS-21



Mr. Munir Ahmed Shaikh  
Director Finance / Member UPC  
BPS-20



Dr. Dur Mohd. Pathan  
Provost Hostel  
BPS-19



Mr. Abdull Jalil Khan  
Member UPC  
BPS-19



Mr. Mushtaq Ahmed P.  
Purchase Officer/Member UPC  
BPS-18

**MEHRAN UNIVERSITY OF ENGINEERING & TECHNOLOGY, JAMSHORO.**

**Comparative Statement for Printing of Following Items**

ANNEXURE-A

Sr. No.	Description	Qty	M/s. Allied Printing Corporation, Hyd.	M/s. Shan Printing Press, Hyd.	M/s. Ali Hussain Process & Printing, Hyd.
<b>01</b>	Hostel Allotment Forms 08 pages single side printing on imported Indonesian offset paper 80 grams, (size 8.5" x 11") with Two Colour Printing of Title Cover on Imported Art Card 260 grams Including serial numbering. As per sample.	<b>7,000 Nos.</b>	18 126,000	15.20 106,400	18 126,000
<b>02</b>	Single page allotment forms both side printing on imported Indonesian offset paper 80 grams, (size 8.5" x 11"). As per sample.	<b>14,000 Nos.</b>	1.10 15,400	0.99 13,860	1.35 18,900
	<b>Total Amount</b>		<b>141,400/-</b>	<b>120,260/-</b>	<b>144,900/-</b>

